Humboldt Bay Harbor District response to additional questions regarding the Invitation for Bids to Replace a 480 Volt, 3 Phase, 200-amp service electrical feed

- Q. Will Any electrical plans be available to contractors? I.e., 1-line diagram, site plans, as built drawings of marina?
- A. Posted to our website 04/01/2021
- Q. Please advise if any spare underground conduits exist to F dock?
- A. There is a spare conduit for a portion of the run which lies between the Main Switch and the pull box at the Head of 'D' Dock. The remaining portion is as existing.

End of questions