



812 W. Wabash Ave., Eureka, CA 95501-2138

707-441-8855

Civil Engineering, Environmental Services, Geosciences, Planning & Permitting, Surveying

Reference: 016240.002

November 30, 2018

**Subject: Humboldt Bay Harbor, Recreation and Conservation District
Debris Cleanup – Redwood Marine Terminal II
Addendum No. 1**

Attention: All Plan Holders and Prospective Bidders:

Attached you will find Addendum Number 1 to the aforementioned project. Addendum 1 is hereafter included in the Contract Documents. Your attention to its content is required.

Regards,

SHN Engineers & Geologists

A handwritten signature in black ink, appearing to read 'M. Foget'.

Michael K. Foget, PE
Senior Civil Engineer

MKF:dla

Enclosure: Addendum No. 1

Reference: 016240.002

Debris Cleanup – Redwood Marine Terminal II Samoa, California

Addendum No. 1

Prepared for:

**Humboldt Bay Harbor,
Recreation and Conservation District**

Bid Opening:

2:00 p.m., December 7, 2018

Humboldt Bay Harbor, Recreation and Conservation District

601 Startare Drive, Eureka, CA 95501

Prepared by:



Engineers & Geologists
812 W. Wabash Ave.
Eureka, CA 95501-2138
707-441-8855

November 2018

QA/QC: 



ADDENDUM NO. 1

November 30, 2018

**Humboldt Bay Harbor, Recreation and Conservation District
Notice of Request for Proposals
Debris Cleanup – Redwood Marine Terminal II, Samoa, California**

A. The following section of the bid package has been modified:

- 1) Technical Specifications Page TS-6, Item 2 - Debris Segregation. Separation of 2,400 cubic yards of construction debris located in three (3) stockpiles for material smaller than a half-inch (1/2) will be required. The separation of this material smaller than a quarter-inch (1/4) no longer applies.**

B. The following questions have been received by the District; District responses are in *italics*:

- 1) Is there a water source near the work Area?**

Yes, water is available for use from a fire hydrant approximately 300 feet from the work area.

- 2) Can concrete be removed for recycling offsite?**

Yes, concrete can be removed from the site for recycling at no additional cost to the District. Provide copies of the agreement between the contractor and the permitted entity that receives, processes, and disposes of the material. Said agreement shall release the District from future responsibility for the material. Any material removed from the site for processing will not be returned for onsite placement.

- 3) What storm water controls are required for this work?**

The grading permit to be acquired by the contractor from the Humboldt County Planning and Building Department will require that the contractor develop and implement an approved Erosion and Sediment Control Plan.

END OF ADDENDUM